

Annual Drinking Water Quality Report-2022
Mobile Gardens Mobile Home Park
25692 North Parkway Road., Seaford, DE 19973
Public Water Supply AD#0000651
June 15, 2023

INTRODUCTION

To comply with State and Federal regulations, Mobile Gardens Mobile Home Park will be annually issuing a report describing the quality of your drinking water. This report provides an overview of the 2022 water quality. Included are the details about where your water comes from, what it contains, and how it compares to State Standards. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. If you have any questions about this report or concerning your drinking water, please contact Vernon Zweifel at 302-629-4959. We want you to be informed about your drinking water, and we will be available to discuss any drinking water issues in person.

WHERE DOES OUR WATER COME FROM?

1. In general, the source of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and can pick up substances resulting from the presence of animals or from human activities.
2. Contaminants that may not be present in source water include:
 - Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
 - Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban storm water runoff, Industrial or domestic wastewater discharge, oil and gas production, mining and farming.
 - Pesticides and herbicides, which may come from a variety of sources, such as agriculture, urban storm runoff and residential uses.
 - Organic chemicals and contaminants, including synthetic and volatile organic chemicals, which are by products of industrial processes and petroleum production, and can also come from gas stations, urban storm runoff and septic systems.
 - Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
3. In order to endure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by the public water system. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for the public health.

FACT AND FIGURES

Our water system serves 500 people through 200 service connections. Our water source is one groundwater well. Our well draws from the Choptank Aquifer. The well is located in the A section near the East end of the shop area. The water is chlorinated prior to distribution.

SOURCE WATER ASSESSMENT

The Delaware Department of Natural resources and Environmental Control's (DNREC) Division of Water Resources has completed the Source Water Assessment for the public water supply wells for Mobile Gardens as required under the 1996 amendments to the Safe Drinking Water Act. This assessment has been performed using the methods specified in the State of Delaware Source Water Assessment Plan (DNREC, 199).

Mobile Gardens uses one well to provide drinking water to the system. This well has a low vulnerability because it withdraws water from the confined Chesapeake aquifer. This well is classified as "Confined" because significant clay layers exist between the ground surface and the well screen. As a confined aquifer well, the wellhead protection area was delineated using a fixed radius of 150 feet.

This public water supply system provides water to an average daily population of 500 residential consumers from January 1 to December 31 through 200 residential service connections.

There is one discrete source of potential contamination in the wellhead protection area for the system residential land uses.

Although water samples may have been taken from within the distribution system, no raw water (well tap) samples have been recorded for this public water system.

Overall, Mobile Gardens #1 has a low susceptibility to nutrients, a low susceptibility to pathogens, a low susceptibility to petroleum hydrocarbons, a low susceptibility to pesticides, no susceptibility to PCB's, no susceptibility to other organic compounds, no susceptibility to metals and no susceptibility to other inorganic compounds.

The report is available in the Park Management Office at 25692 North Parkway Road., Seaford, DE 19973

Monday through Friday 8:00am- 4:00pm. The phone number is 302-629-4959. You may also review this at <http://delawaresourcewater.org/assessments/>.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, volatile organic compounds and synthetic organic compounds. The table depicts which compound were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentration of these contaminants do not change frequently. Some of our data, though representative are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 425-4791.

*Lead: if present, elevated levels of lead can cause serious health problems, especially for pregnant woman and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Mobile Gardens Mobile Home Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When water has been sitting for a couple of hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

DEFINITIONS:

Maximum contaminant level (MCL): The highest level of contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible.

Maximum contaminants level Goal (MCGL): The level of contaminant that is allowed in drinking water below which there is no know or expected risk to health. MCLG's allow for a margin of safety.

Action Level (AL): The concentration of contaminant, which if exceed, trigger treatment or other requirements, which a water system must follow.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million-ppm)

Micrograms per liter (ug/l) or Parts Per Billion (ppb): Corresponds to one part of liquid in one billion part of liquid (parts per billion-ppb). Or one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000.00.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in the drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contamination.

Non-Detect (ND): laboratory analysis indicates that the constituent is not present.

MONITORING OR REPORTING VIOLATIONS:

We routinely test for various contaminants in the water supply to comply with the regulatory requirements, and our reports are submitted to the Delaware Health and Social Services- Division of Public Health as required.

IS OUR WATER SAFE FOR EVERYONE? DO I NEED TO TAKE PRECAUTION?

It should be noted that some people may be more vulnerable to contaminants in drink water than the general population. Immune-compromised person such as person with cancer undergoing chemotherapy, person who have undergone organ transplants, people with HIV/AIDS or other immune disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about the drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). Please note that testing of the water at this system has shown that this water is suitable for drinking purposes and contains very low amounts of contaminants and should not pose any health risk.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some costs associated with both of these necessities of life.
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells; pumping systems and water towers;
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid sever water restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservations tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off tap water when brushing teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15-20 gallons a day. Fix it and you can save almost 6,000 gallons a year.
- Check your toilets for leaks by putting a few drops of food coloring in your tank watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue provide your family with clean, quality water this year. In order to maintain a safe and dependable water supply, we sometimes need to make improvement that will benefit all our customers. We ask that all our customers help us protect our water source, which are the heart of our community, our way of life and our children's future. Please call our office if you have any questions.

TEST RESULTS

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2021	1.7	.8-1.7	MRDLG=4	MRDL=4	ppm	N	water additive used to control microbes
Total Trihalomethanes(TTHM)	8/24/2021	5.7	5.7-5.7	No goal for the total	80	ppb	N	By-product of drinking water disinfection
Halocetic Acids (HAAS) *	2019	4.149	4.149-4.149	No goal for the total	60	ppb	N	By-product of drinking water disinfection
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violations	Likely Source of Contamination
Fluoride	2022	0.4	0.3591-0.3591	2	2	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as nitrogen]	2021	0.1831	0-0.1831	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage;Erosion of natural deposits
Nitrite [measured as nitrogen]	2021	0.1831	0-0.1831	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage;Erosion of natural deposits
Unregulated inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Alkalinity	2/21/2022	269.92	269.92-269.92	N/A	N/A	ppm	N	Naturally Occurring
Chloride	2/21/2022	21.8946	21.8946-21.8946	250	N/A	ppm	N	Naturally Occurring
Sodium	2/21/2022	104.1	104.1-104.1	N/A	N/A	ppm	N	Naturally Occurring
Sulfate	2/21/2022	3.378	3.378-3.378	250	N/A	ppm	N	Naturally Occurring
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	7/20/2020	1.3	1.3-1.3	0	5	pCi/L	N	Erosion of Natural Deposits
Lead and Copper	Date Sampled	MCLG 90th percentiled	Action Level (AL)	90th Percentile	sites over a	Units	Violation	Likely Source of Contamination
Copper	8/6/2018	1.3	1.3	0.251	0	ppm	N	Erosion of natural deposits; leaching from wood perservatives Corrosion of household plumbing systems
Lead	8/6/2018	0	15	10.2	0	ppb	N	Corrosion of household plumbing systems; Erosion of Natural Deposits

